

CERTIFICATE OF COMPLIANCE

Certificate Number EX27817
Report Reference EX27817-20180628
Issue Date 2019-DECEMBER-19

Issued to: THAI PREMIUM PIPE CO., LTD.
45 M. 2 T. Chaimongkol, A. Mueang Samut Sakhon
Samut Sakhon 74000 THAILAND

**This certificate confirms that
representative samples of**

METALLIC SPRINKLER PIPE
SEE ADDENDUM PAGE

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety:
Additional Information:

UL 852 Metallic Sprinkler Pipe for Fire Protection Service
See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information.

This Certificate of Compliance does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number EX27817
Report Reference EX27817-20180628
Issue Date 2019-DECEMBER-19

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Schedule 10 (black or galvanized) steel pipe in the 3/4, 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 3-1/2, 4, 5 and 6 in. sizes as per ASTM A795, Grade A, Type E.

Schedule 40 (black or galvanized) steel pipe in the 3/4, 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 3-1/2, 4, 5 and 6 in. sizes as per ASTM A53, Grade A, Type E.

Model TPP SCH-7 Steel pipe in the 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 4 and 6 in nominal diameter for wet, dry preaction and deluge type sprinkler systems with unthreaded ends intended to be joined by welding or by Listed rubber gasketed fittings as indicated in the individual Listings under the category for Fittings, Rubber Gasketed (VIZM) when installed in accordance with the fitting manufacturer's specifications where rated pressure and corrosion resistance ratios (CRR) are as follows:

Pipe Size In.	Rated Pressure (psig)	CRR Unthreaded
1	300	2.14
1-1/4	300	1.37
1-1/2	300	2.03
2	300	1.65
2-1/2	300	1.06
3	300	1.05
4	300	0.67
6	300	0.50

All pipes with threaded ends shall conform to ANSI B1.20.1.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

